

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR
QUEBEC

MANUFACTURERS NAME: <u>Shurjoint Metals Inc.</u>	
MANUFACTURERS ADDRESS: <u>No. 295 Sec. 3 Wandan Road, Wandan Hsiang, Pinglung Hsien, Taiwan</u>	
PLANT LOCATIONS: <u>Same as above (Note: LRQA do not list street name and number on the certificate, only main location)</u>	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input checked="" type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p>TITLE OF THE STANDARD OF CONSTRUCTION</p> <p>ASME B31.3</p>
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT	
and / or SHURJOINT	
TYPE OF CONSTRUCTION	
FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input checked="" type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:	
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <ol style="list-style-type: none"> Lloyd's Register Quality Assurance Certificate #TWN0955771. Renew 0B1967.7C and include additions. See attachment 1, drawings & proof test records. 	

DECLARATION:

I WANG, HUI-PING (see note 3) employed by Shurjoint Metals Inc. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by Lloyd's Register Quality Assurance as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: *Wang Hui-Ping*
 Declared before me at Taipei, R.O.C.
 This 26 day of JAN 2011 AD
 Commissioner of Oaths or Notary Public: (sign) *[Signature]*

CHOU, CHIA-YIN
 NOTARY PUBLIC
 The Equated Notary Public Office
 of Taiwan Taipei District Court, R.O.C.
 6F No. 6, Siang-Yang Road, Chung-Cheng
 District, Taipei City 100, Taiwan
 Case No. 00年度北院民地字第200164

This space for Regulatory Authority use This registration must be revalidated after ten (10) years from	GOVERNMENT OF NEWFOUNDLAND AND LABRADOR Department of Government Services Registered <u>0B1967.70 Rev. 1</u> Date <u>2011/2/16</u> GOVERNMENT SERVICE CENTRE Engineering and Inspection Services Registered by <u><i>[Signature]</i></u> UNDER THE AUTHORITY OF THE PUBLIC SAFETY ACT AND THE BOILER, PRESSURE VESSEL AND COMPRESSED GAS REGULATIONS
CRN: <u>0B1967.7 Rev.1</u> FID#: <u>1834</u>	
<p>Notes:</p> <ol style="list-style-type: none"> All fittings shall be registered in the name of the Manufacturer. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. 	



THIS IS PART OF
 CRN 0B1967.71
 Journal # 51712
 BCSA

505 - 6th Street, Suite 200
 New Westminster, B. C. V3L 0E1

Toll Free: 1-866-566-SAFE
 Fax: (778) 396-2064
 www.safetyauthority.ca

CRN Registration

Jan. 18, 2011

Attachment #1

Shurjoint Grooved Components are to be registered (Category B - Flanges)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawings
7043 Flange ANSI Class 300	2", 2½", 3", 4", 5", 6", 8", 10", 12"	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-7043 H143 G14a 7041HB
7180	3x2, 4x2.5 4x3, 4x6	125	-20F - +180F	1 AS


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT



NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES



NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Shurjoint Metals Inc.	
MANUFACTURERS ADDRESS: 489 Wantan Rd., Wantan Hsiang, Pingtung Hsien, Taiwan, R.O.C.	
PLANT LOCATIONS: As above. (Note: LRQA do not list street name & number on certificates. Only main location)	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY	TYPE OF THE STANDARD OF CONSTRUCTION
A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input checked="" type="radio"/> B Flanges: all flanges C Valves: all line valves D Expansion joints, flexible connections, and hose assemblies: all types E Strainers, filters, separators, and steam traps F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs H Pressure retaining components that do not fall into one of the above categories N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> . (Meeting AECS or ASME requirements)	ASME B 31.3
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT	TYPE OF CONSTRUCTION
 and/or SHURJOINT	FORCED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:	
LRQA certificate of approval. No: TWN0955771. ABS Consulting report No. 06-024-TA dated July 16, 2006, No. 06-031-TA with supporting drawings, tensile test records, calculations and proof test certificates. Items to be registered: SS-41 flanges, SS-80 universal flange adapters, C341 flanges.	

DECLARATION:
 I Amy Wang (and wife) employed by Shurjoint Metals Inc. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by LRQA certificate No. TWN0955771 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: 
 Declared before me at Taipei
 This 24th day of November AD 2006
 Witnessed on Nov 24 2006
 Commissioner of Oaths or Notary Public: (sign) 
 Name: Holly [unclear]
 Position: Deputy Director
Administration and Consular Services
Canadian Trade Office in Taipei



This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance	 GOVERNMENT OF NEWFOUNDLAND AND LABRADOR Department of Government Services Registered <u>OB1967.7</u> Date <u>12/18/2006</u> GOVERNMENT SERVICE CENTRE Engineering and Production Services Registered by <u></u> UNDER THE AUTHORITY OF THE PUBLIC SAFETY ACT AND THE BOILER, PRESSURE VESSEL AND SOLIDIFIED GAS REGULATIONS
CRN: <u>OB1967.7</u> FID#: <u>1834</u>	
Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.	