


**UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS**

NEW BRUNSWICK  
NUNAVUT

NOVA SCOTIA  
YUKON

PRINCE EDWARD ISLAND  
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR  
QUEBEC

MANUFACTURERS NAME: Shurjoint Metals Inc.	
MANUFACTURERS ADDRESS: No. 295 Sec. 3 Wandan Road, Wandan Hsiang, Pingtung Hsien, Taiwan	
PLANT LOCATIONS: Same as above (Note: LRQA do not list street name and number on the certificate, only main location)	
<p align="center"><b>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</b></p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers  <input checked="" type="radio"/> B Flanges: all flanges                  C Valves: all line valves                  D Expansion joints, flexible connections, and hose assemblies: all types                  E Strainers, filters, separators, and steam traps                  F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters                  G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs                  H Pressure retaining components that do not fall into one of the above categories                  N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p align="center"><b>TITLE OF THE STANDARD OF CONSTRUCTION</b></p> <p>ASME B31.3</p>
<p align="center"><b>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</b></p> <p align="center"> and / or <b>SHURJOINT</b></p>	<p align="center"><b>TYPE OF CONSTRUCTION</b></p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/>                  CAST <input checked="" type="checkbox"/> OTHER <input type="checkbox"/>                  DESCRIBE OTHER:</p>
<p align="center"><b>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</b></p> <p>1. Lloyd's Register Quality Assurance Certificate #TWN0955771.                  2. Renew OB1967.7C and include additions.                  3. See attachment 1, drawings &amp; proof test records.</p>	


**DECLARATION:**

I WANG, HUI-PING (see note 3) employed by Shurjoint Metals Inc. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by Lloyd's Register Quality Assurance as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: 

Declared before me at Taipei, R.O.C.

This JAN 26 2011 day of JAN AD 2011

Commissioner of Oaths or Notary Public: (sign) 

**CHOU, CHIA-YIN**  
NOTARY PUBLIC

The Equipped Notary Public Office  
of Taipei District Court, R.O.C.  
6F No. 6, Siang-Yang Road, Chung-Cheng  
District, Taipei City 100, Taiwan

**Case No. 100年度北院民認第200164**


This space for Regulatory Authority use

This registration must be revalidated after ten (10) years from the date of acceptance.

CRN: OB1967.7 Rev.1

FID#: 1834

Notes:  
 1. All fittings shall be registered in the name of the Manufacturer.  
 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.  
 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product.  
 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.



GOVERNMENT OF YUKON  
BOILERS BRANCH  
CRN OB1967.74 REV1  
DATE 14/02/11



THIS IS PART OF  
 CRN 0B1967.71  
 Journal # 51712  
 BCSA

505 - 6<sup>th</sup> Street, Suite 200  
 New Westminster, B. C. V3L 0E1

Toll Free: 1-866-566-SAFE  
 Fax: (778) 396-2064  
 www.safetyauthority.ca

## CRN Registration

Jan. 18, 2011

Attachment #1

Shurjoint Grooved Components are to be registered (Category B - Flanges)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawings
7043 Flange ANSI Class 300	2", 2½", 3", 4", 5", 6", 8", 10", 12"	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-7043 H143 G14a 7041HB
7180	3x2, 4x2.5 4x3, 4x6	125	-20F - +180F	1 AS


**UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS**

NEW BRUNSWICK  
NUNAVUT

NOVA SCOTIA  
YUKON

PRINCE EDWARD ISLAND  
NORTHWEST TERRITORIES


NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: <u>Shurjoint Metals Inc.</u>	
MANUFACTURERS ADDRESS: <u>489 Wantan Rd., Wantan Hsiang, Pingtung Hsien, Taiwan, R.O.C.</u>	
PLANT LOCATIONS: <u>As above. (Note: LRQA do not list street name &amp; number on certificates. Only main location)</u>	
<p align="center"><b>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</b></p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers  <input checked="" type="checkbox"/> B Flanges: all flanges                  C Valves: all line valves                  D Expansion joints, flexible connections, and hose assemblies: all types                  E Strainers, filters, separators, and steam traps                  F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters                  G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs                  H Pressure retaining components that do not fall into one of the above categories                  M Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>. (Meeting AECB or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p align="center"><b>ASME B 31.3</b></p>
SHOW MANUFACTURER'S NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT	
 and/or SHURJOINT	
TYPE OF CONSTRUCTION	
FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:	
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:	
LRQA certificate of approval No. TWN0965771. ABS Consulting report No. 06-024-TA dated July 16, 2006, No. 06-031-TA with supporting drawings, tensile test records, calculations and proof test certificates. Items to be registered: SS-41 flanges, SS-80 universal flange adapters, C341 flanges.	

**DECLARATION:**

I Amy Wang (see note 5) employed by Shurjoint Metals Inc. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by LRQA certificate No. TWN0965771 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: *Amy Wang*  
 Declared before me at Taipei  
 This 24th day of November AD 2006  
 Witnessed on Nov 24, 2006  
 Commissioner of Oaths or Notary Public: (sign) *[Signature]*  
 Name: Holly Chan  
 Position: Deputy Director  
Administration and Consular Services  
Canadian Trade Office in Taipei



This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0B1967.7</u>	
FID#: <u>1834</u>	
Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.	