

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR
QUEBEC

MANUFACTURERS NAME: Shurjoint Metals Inc.	
MANUFACTURERS ADDRESS: No. 295 Sec. 3 Wandan Road, Wandan Hsiang, Pingtung Hsien, Taiwan	
PLANT LOCATIONS: Same as above (Note: LRQA do not list street name and number on the certificate, only main location)	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers B Flanges: all flanges <input checked="" type="radio"/> C Valves: all line valves D Expansion joints, flexible connections, and hose assemblies: all types E Strainers, filters, separators, and steam traps F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs H Pressure retaining components that do not fall into one of the above categories N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>, (Meeting CNSC or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p>ASME B31.3</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <div style="text-align: center;"> and / or SHURJOINT Grinnell <small>A Tyco International Company</small> </div>	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input checked="" type="checkbox"/> DESCRIBE OTHER:</p>
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>1. Lloyd's Register Quality Assurance Certificate #TWN0955771. 2. Renew OC1968.7C and add the Grinnell trademark and additions. 3. See attachment 1, drawings & proof test records.</p>	

DECLARATION:

I WANG, HUI-PING (see note 3) employed by Shurjoint Metals Inc. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by Lloyd's Register Quality Assurance as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: *Wang Hui-Ping*
 Declared before me at Taipei, R. O. C.
 This 26 day of JAN 2011 AD
 Commissioner of Oaths or Notary Public: (sign) *[Signature]*

CHOU, CHIA-YIN
 NOTARY PUBLIC
 The Equated Notary Public Office
 of Taiwan Taipei District Court, R.O.C.
 6F No. 6, Siang-Yang Road, Chung-Cheng
 District, Taipei City 100, Taiwan
 Case No. 100年度北院民認實字 200167

<p align="center">This space for Regulatory Authority Use</p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p>CRN: <u>OC1968.7 Rev.1</u></p> <p>FID#: <u>1834</u></p> <p>Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.</p>	<p align="center">BRUNSWICK DEPT OF PUBLIC SAFETY BOILER & PRESSURE VESSEL ACT</p> <p align="center">REGISTRATION ONLY</p> <p align="center">CRN <u>OC1968.7 Rev.1</u></p> <p>EXAMINER <u><i>[Signature]</i></u> for CHIEF BOILER INSPECTOR</p> <p>DATE: <u>Feb 8/2011</u></p>
---	---

FITTINGS COMPONENTS
 FITTINGS COMPONENTS

Newfoundland
Labrador

GOVERNMENT OF
NEWFOUNDLAND
AND LABRADOR
Department of
Government Services

Registered OC 1968.70 Rev.1
Date 2011/2/16 Jan. 18, 2011

GOVERNMENT SERVICES CENTRE
Engineering and Inspection Services

Registered by [Signature]

CRN Registration

Attachment #1


Shurjoint Grooved Components are to be registered (Category C - Valves)

Model Number	Size Range (inch)	Rated Pressure (psi)	Material	Drawings
✓ RCV Riser Check Valve	2½", 3", 4", 5", 6"	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJCV ✓ 1RVa ✓ 1RVb ✓ 1RVc ✓ 1RVd ✓ 1RVe ✓ 1RVf ✓
	8"	125		AS-SJ2000 ✓ 1JNa ✓ 1JNb ✓ 1JNc ✓ 1JNd ✓
✓ SJ-200 Low Profile Butterfly Valve	2", 2½", 3", 4", 6"	125	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJ300F ✓ AS-SJ300F-a ✓ 1JLa ✓ 1JLb ✓ 1JLc ✓ 1JLd ✓ 1JLe ✓ 1JLf ✓ 1JFj ✓
✓ SJ-300F Resilient Seated Butterfly Valve	2½", 3", 4", 5", 6"	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJ900 ✓ 1J9a ✓ 1RVb ✓ 1RVc ✓ 1RVd ✓ 1Rve ✓ 1RVf ✓
✓ SJ-500L Ball Valve	1½", 2", 2½", 3"	250	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	SJ500-C-3 ✓
	4", 6"	200		
✓ SJ-900 Swing Check Valve	2½", 3", 4", 5", 6"	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJ930 ✓ 1AJa ✓ 1AJb ✓ 1AJc ✓ AS-7771 ✓ H108a ✓ AS-XH70EP ✓ H1X8 ✓ G15a ✓ 7705TB ✓ 160a ✓ S819001 ✓
	8"	150		
✓ SJ-930 Horizontal Swing Check Valve	2", 2½", 3", 4"	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-SJ915 ✓ AS-SJ915_b ✓ 1JKa ✓ 1JKd ✓ 1JKb ✓ 1JKc ✓ 1JKe ✓
✓ SJ-915 Dual Disc Check Valve	2½", 3", 4", 6", 8"	300	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	
	10", 12"	150		
	14", 16", 18", 20", 24"	100		

UNDER THE AUTHORITY OF THE
PUBLIC SAFETY ACT AND
THE BOILER, PRESSURE VESSEL AND
COMPRESSED GAS REGULATIONS

Grinnell Grooved Components are to be registered (Category C -Valves)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawing and Revision
835 Ball Valve	1½", 2", 2½", 3"	250	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	SJ500-C-3
	4", 6"	200		
680 Grooved End Copper Butterfly Valve	2", 2-1/2", 3", 4", 5", 6"	150	EPDM: -4°F ~ +230°F (-20°C ~ +110°C)	SJ-C300 1CKa 1CKb 1CKc


**GOVERNMENT OF
NEWFOUNDLAND
AND LABRADOR**
 Department of
Government Services

Registered DC1968.70 Rev.1
 Date 2011/2/16

GOVERNMENT SERVICES CENTRE
 Engineering and Inspection Services

Registered by [Signature]

**UNDER THE AUTHORITY OF THE
PUBLIC SAFETY ACT AND
THE BOILER, PRESSURE VESSEL AND
COMPRESSED GAS REGULATIONS**


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Shurjoint Metals Inc.	
MANUFACTURERS ADDRESS: 489 Wantan Rd., Wantan Hsiang, Pingtung Hsien, Taiwan, R.O.C.	
PLANT LOCATIONS: As above. (Note: LRQA do not list street name & number on certificates. Only main location)	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers B Flanges: all flanges <input checked="" type="checkbox"/> C Valves: all line valves D Expansion joints, flexible connections, and hose assemblies: all types E Strainers, filters, separators, and steam traps F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs H Pressure retaining components that do not fall into one of the above categories N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting AECB or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p align="center" style="font-size: 1.2em;">ASME B 31.3</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <p align="center">  and/or SHURJOINT </p>	<p>TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input checked="" type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:</p>
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <ul style="list-style-type: none"> - LRQA certificate of approval. No: TWN0955771/ Chin Hsin Machinery Industry Co., Ltd certificate of registration No. AJA99/1696. (NOTE: Shurjoint designs the valves and casts the DI bodies. Shurjoint trademark is on all valve bodies in all materials. Chin Hsin is the subcontractor producing the finished valves) - ABS Consulting reports No. 06-024-TA dated July 16, 2006, 06-031-TA with supporting drawings, tensile test records, calculations and proof test certificates. - Items to be registered: SJ-C300, SJ-300N, SJ-400, SJ-600 	

DECLARATION:


I Amy Wang (see note 3) employed by Shurjoint Metals Inc. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by LRQA certificate No. TWN0955771 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: *Amy Wang*

Declared before me at Taipei on 24 day of November AD 2006

This 24th day of November AD 2006

Commissioner of Oaths or Notary Public (sign): *Holly Kwan*
 Deputy Director
 Administration and Consular Services
 (Place Official seal to the right)
 Canadian Trade Office in Taipei



This space for Regulatory Authority use
 This registration must be revalidated after ten (10) years from the date of adoption

CRN: 0C1968.7

FID#: 1834

- Notes:
1. All fittings shall be registered in the name of the Manufacturer.
 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.
 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product.
 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.

PROVINCE OF NB
DEPT. OF PUBLIC SAFETY
BOILER & PRESSURE VESSEL ACT

REGISTRATION ONLY

CRN 0C1968.7

EXAMINER: *Paul E. Ross*
 for
 CHIEF BOILER INSPECTOR

DATE: Dec 7 2006

BLRs PV's
 FITTINGS COMPONENTS