


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON



PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR
QUEBEC


MANUFACTURERS NAME: Shurjoint Metals Inc.	
MANUFACTURERS ADDRESS: No. 295 Sec. 3 Wandan Road, Wandan Hsiang, Pingtung Hsien, Taiwan	
PLANT LOCATIONS: Same as above (Note: LRQA do not list street name and number on the certificate, only main location)	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers B Flanges: all flanges C Valves: all line valves <input checked="" type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types E Strainers, filters, separators, and steam traps F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs H Pressure retaining components that do not fall into one of the above categories N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>, (Meeting CNSC or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p>ASME B31.3</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <p align="center"> and / or SHURJOINT</p>	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input checked="" type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:</p>
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>1. Lloyd's Register Quality Assurance Certificate #TWN0955771. MODEL 650N 2. See attachment 1, drawings & proof test records. DWG# 165 REV. ---</p>	

DECLARATION:

I WANG, HUI-PING (see note 3) employed by Shurjoint Metals Inc. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by Lloyd's Register Quality Assurance as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: 
 Declared before me at Taipei, R. O. C.
 This JAN 26 day of 2011 AD
 Commissioner of Oaths or Notary Public: (sign) 

CHOU, CHIA-YIN
 NOTARY PUBLIC
 The Equated Notary Public Office
 of Taiwan Taipei District Court, R.O.C.
 6F No. 6, Siang-Yang Road, Chung-Cheng
 District, Taipei City 100, Taiwan
 Case No. 一〇〇年度北院民認字 200170

<p align="center">This space for Regulatory Authority use</p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p>CRN: <u>OD.02480.76</u></p> <p>FID#: _____</p> <p>Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.</p>	<p align="center">QUEBEC</p> <p align="center">ENREGISTRÉ EN VERTU DE LA LOI A.S.P. CHAP. A 20.01</p> <p align="center">OD02480.76</p> <p align="center">NEC / CRN _____</p> <p>SIGN: <u></u></p> <p align="center">DATE: <u>3 AVR 2011</u></p>
--	--

CRN Registration

Jan. 18, 2011

Shurjoint Grooved Components are to be registered (Category D – Expansion Joints)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawing
650N Expansion Joint	2", 2½", 3", 4", 6"	175	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	165