


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK  
NUNAVUT

NOVA SCOTIA  
YUKON



PRINCE EDWARD ISLAND  
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR  
QUEBEC

MANUFACTURERS NAME: Shurjoint Metals Inc.	
MANUFACTURERS ADDRESS: No. 295 Sec. 3 Wandan Road, Wandan Hsiang, Pingtung Hsien, Taiwan	
PLANT LOCATIONS: Same as above (Note: LRQA do not list street name and number on the certificate, only main location)	
<b>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</b> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers B Flanges: all flanges C Valves: all line valves D Expansion joints, flexible connections, and hose assemblies: all types <input checked="" type="radio"/> E Strainers, filters, separators, and steam traps F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs H Pressure retaining components that do not fall into one of the above categories N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)	<b>TITLE OF THE STANDARD OF CONSTRUCTION:</b>  ASME B31.3
<b>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</b>   and / or <b>SHURJOINT</b>	<b>TYPE OF CONSTRUCTION</b> FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
<b>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</b> 1. Lloyd's Register Quality Assurance Certificate #TWN0955771. 2. Renew OE1965.7C and include additions 3. See attachment 1, drawings & proof test records.	

DECLARATION:

I WANG, HUI-PING (see note 2) employed by Shurjoint Metals Inc. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by Lloyd's Register Quality Assurance as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer:   
 Declared before me at Taipei, R. O.C.  
 This JAN 26 2011 day of JAN 26 2011 AD  
 Commissioner of Oaths  
 or Notary Public: (sign) 



**CHOU, CHIA-YIN**  
 NOTARY PUBLIC  
 The Educated Notary Public Office  
 of Taiwan Taipei District Court, R.O.C.  
 6F No. 6, Siang-Yang Road, Chung-Cheng  
 District, Taipei City 100, Taiwan  
 Case No. 100年度北院民認字第200173

This space for Regulatory Authority use

This registration must be revalidated after ten (10) years from the date of acceptance

CRN: OE1965.7 Rev.1  
 FID#: 1834

Notes:  
 1. All fittings shall be registered in the name of the Manufacturer.  
 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.  
 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product.  
 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.

  
 Date: Feb. 11/11  
 C.R.N. OE1965.78REV1  
 Dwg. as described  
 Signed Yvonne Perry  
 1 of 1  
 Part  




**THIS IS PART OF  
CRN 0E1965.71  
Journal # 51359  
BCSA**

505 - 6<sup>th</sup> Street, Suite 200  
New Westminster, B. C. V3L 0E1


Toll Free: 1-866-566-SAFE  
Fax: (778) 396-2064  
www.safetyauthority.ca

## CRN Registration

Jan. 18, 2011

Shurjoint Grooved Components are to be registered (Category E - Strainers)

Model Number	Size Range (inch)	Rated Pressure (psi)	Service Temperature	Drawing
726 Y-Strainers	2", 2½", 3", 4", 5", 6"	200	EPDM: -20°F ~ +180°F (-29°C ~ +82°C)	AS-726 166 160a 160c
	8"	100		AS-7705B H105 AS-7771 H108b
	10", 12", 14", 16"	75		68 G15a G15b 7705TB S819001

<b>MANUFACTURERS NAME:</b> Shurjoint Metals Inc.	
<b>MANUFACTURERS ADDRESS:</b> 489 Wantan Rd., Wantan Hsiang, Pingtung Hsien, Taiwan, R.O.C.	
<b>PLANT LOCATIONS:</b> As above. (Note: LRQA do not list street name & number on certificates. Only main location)	
<b>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</b>	<b>TITLE OF THE STANDARD OF CONSTRUCTION</b>
<input type="checkbox"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input type="checkbox"/> B Flanges: all flanges <input type="checkbox"/> C Valves: all line valves <input type="checkbox"/> D Expansion joints, flexible connections, and hose assemblies: all types <input checked="" type="checkbox"/> E Strainers, filters, separators, and steam traps <input type="checkbox"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters <input type="checkbox"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs <input type="checkbox"/> H Pressure retaining components that do not fall into one of the above categories <input type="checkbox"/> I Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting AECB or ASME requirements)	<b>ASME B 31.3</b>
<b>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</b>	<b>TYPE OF CONSTRUCTION</b>
 and/or SHURJOINT	FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
<b>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</b>	
- LRQA certificate of approval. No: TWN0955771 - ABS Consulting reports No. 06-024-TA dated July 16, 2006 with supporting drawings, tensile test records, calculations and proof test certificates. - Items to be registered: C726 & SS-726 Y strainers	

**DECLARATION:**

I, Amy Wang (see note 3) employed by Shurjoint Metals Inc. and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by LRQA certificate No. TWN0955771 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer:   
 Declared before me at Taipei

This 24th day of November AD 2006

Commissioner of Oaths based on NOV 24 2006  
 or Notary Public: (sign) \_\_\_\_\_


(Affix Official seal to the right)  
 Name: Emily Kwan  
 Position: Deputy Director  
Administration and Consular Services  
Canadian Trade Office in Taipei



This space for Regulatory Authority use  
 This registration must be revalidated after ten (10) years from the date of acceptance.

CRN: OE1965.7  
 FID#: 1834

Notes:  
 1. All fittings shall be registered in the name of the Manufacturer.  
 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.  
 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product.  
 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.

  
 Date: Dec. 8/06  
 C.R.N. OE1965.78  
 Dwg. as described  
 Signed Yvonne Perry  
